

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, AVERAGE / ARSENIC**

The Texas Commission on Environmental Quality (TCEQ) has notified the Spring Creek Pure public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for arsenic. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic to be 0.010 milligrams per liter (mg/L) based on the running annual average (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in the **3rd Quarter 2023** of **0.021** mg/L for Spring Creek Loop/ Conway Rd

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

As a component of the continuous action plan, raw water samples will be taken to monitor arsenic in a pilot study at this facility to ensure the level is reduced to below the MCL. Also, the public water system is in the process of drilling a new well and installing filters to reduce arsenic levels.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Undine LLC at 713-574-5953

Posted /Delivered on: 3-6 2025

Instructions for preparing the required Public Notice:

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than 30 days after the violation was identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.